Study Article

Improving the Quality of Power from Grid Connected Renewable Energy Sources

CH.DIVYAKRISNA
B Tech Student
Dept of EEE
SVS Institute of Technology
Warangal, T.S, India

B. ARUNA
B Tech Student
Dept of EEE
SVS Institute of Technology
Warangal, T.S, India

B.SOUJANYA
B Tech Student
Dept of EEE
SVS Institute of Technology
Warangal, T.S, India

B.KARTHIK
B Tech Student
Dept of EEE
SVS Institute of Technology
Warangal, T.S, India

M. SUMAN
B Tech Student
Dept of EEE
SVS Institute of Technology
Warangal, T.S, India

Abstract : **In disseminated framework, renewable Energy Sources (RES) are progressively joined utilizing power hardware interfaces. Broad utilization of force gadgets produce harmonic current and mightdiminish nature of force. In this paper, renewable Energy Sources (RES) is associated with the network through a matrix interfacing inverter for force quality change. The matrix interfacing inverter is associated with a 3-stage 4-wire framework and hysteresis current control strategy is utilized to create door beats. Here renewable Energy Sources (RES) is spoken to as a dc source. The lattice interfacing inverter has the ability of infusing RES energy to the framework furthermore diminishes load unbalance, load sounds and responsive force interest is adjusted. All out Harmonic Distortion (THD) of the lattice associated framework is broke down. The reproduction has been completed in MATLAB/Simulink**

Keywords: **Grid interfacing inverter, Hysteresis Current control, Power Quality Improvement, Renewable Energy Resources (RES).**

INTRODUCTION

Today electric utilities clients of electric force are getting to be expanding everyday worried about taking care of the developing vitality demand. Seventy five percent of aggregate worldwide vitality interest is supplied by the smoldering of fossil energizes. Be that as it may, expanding air contamination, an Earth-wide temperature boost concerns, lessening fossil powers and their expanding cost have made it important to look towards renewable sources as a future vitality arrangement.

For as long as decade, there has been a gigantic enthusiasm for some nations in renewable vitality for force era. The business sector liberalization and government's motivations have further quickened the renewable vitality part development Renewable vitality source coordinated at the appropriation level is termed as circulated era[1].

control innovation, the DG frameworks can now be effectively controlled to upgrade the framework operation with enhanced PQ at the purpose of basic coupling (PCC). Be that as it may, the broad utilization of force gadgets based gear and nonlinear burdens at PCC create symphonious streams, which might disintegrate the nature of force. frameworks. As of late, a couple control procedures for framework associated inverters consolidating PQ arrangement have been proposed. [1], [2]. In [3] an inverter works as dynamic inductor at a specific recurrence to retain the consonant current. In any case, the careful computation of system inductance continuously is troublesome and might crumble the control execution. A comparative methodology in which a shunt dynamic channel goes about as dynamic conductance to sodden out the sounds in the circulation system is proposed in [4]. In [5], a control procedure for renewable interfacing inverter based, on – hypothesis is proposed. In this technique, both burden and inverter current detecting is required to repay the heap current sounds.

Here, the fundamental thought is the greatest usage of inverter rating, which is more often than not underutilized because of the discontinuous way of RES. It is appeared in this paper the network interfacing inverter can adequately be used to perform taking after essential capacities: 1) Transfer of dynamic force gathered from the renewable assets (wind, sun oriented, and so forth) 2) Load responsive force request support. 3) Current music remuneration at PCC. 4) Current unbalance and unbiased current remuneration in the event of 3-stage 4-wire framework.

Study Article

P-Q THEORY BASED CONTROL STRATEGY

A. CONTROL STRATEGY

This hypothesis, otherwise called "immediate receptive force hypothesis" was proposed in 1983 by Akagi etal. (Hirfumi 1983 and Hirfumi1984) to control dynamic channels. It in light of an arrangement of momentary forces characterized in time space. No confinements are forced on the voltage or current waveforms, and it can be connected to three-stage frameworks with or without a nonpartisan wire for three-stage nonexclusive voltage and current waveforms. Along these lines, it is legitimate in relentless state, as well as in transient states.



Fig 1.The p-q theory based control algorithm block diagram for the three phase three leg APF

The Clarke Transformation (Hirfumi 1999) of three-phase generic voltages and load currents are given by

$$\begin{bmatrix} V_0 \\ V_\alpha \\ V_\beta \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} \\ 1 & \frac{-1}{\sqrt{2}} & \frac{-1}{\sqrt{2}} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \end{bmatrix} \begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} \quad (1)$$

$$\begin{bmatrix} i_{L0} \\ i_{L\alpha} \\ i_{L\beta} \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} \\ 1 & \frac{-1}{\sqrt{2}} & \frac{-1}{\sqrt{2}} \\ 0 & \frac{\sqrt{3}}{2} & -\frac{\sqrt{3}}{2} \end{bmatrix} \begin{bmatrix} I_{La} \\ I_{Lb} \\ I_{Lc} \end{bmatrix} \quad (2)$$

Instantaneous real power (p), imaginary power (q) and zero sequence power (p0) are calculated as Eq.

$$\begin{bmatrix} P_0 \\ P \\ q \end{bmatrix} = \sqrt{\frac{2}{3}} \begin{bmatrix} V_0 & 0 & 0 \\ 0 & V_\alpha & V_\beta \\ 0 & -V_\beta & V_\alpha \end{bmatrix} \begin{bmatrix} i_0 \\ i_\alpha \\ i_\beta \end{bmatrix} \quad (3)$$

The total instantaneous power (p3) in 3-phase 3-wire system is calculated as sum of instantaneous real and zero-sequence power.

$$p_3 = P + p_0 = v_0 i_0 + v_\alpha i_{\beta\alpha} + v_\beta i_\beta = v_a i_a + v_b i_b + v_c i_c \quad (4)$$

The instantaneous real and imaginary powers include AC and DC values and can be expressed as follows:

$$p = \bar{p} + \tilde{p} = \bar{p} + p_{2av} + p_{2c}$$
$$q = \bar{q} + \tilde{q} = \bar{p} + q_{2av} + q_{2c} \quad (5)$$

Introduction To Fuzzy Logic Controller

Another dialect was created to depict the fluffy properties of reality, which are exceptionally troublesome and at some point even difficult to be portrayed utilizing customary strategies. Fluffy set hypothesis has been generally utilized as a part of the control territory with some application to dc-to-dc converter framework. A basic fluffy rationale control is developed by a gathering of guidelines in view of the human information of framework conduct. Matlab/Simulink recreation model is worked to examine the dynamic conduct of converter.

Moreover, outline of fluffy rationale controller can give attractive both little flag and substantial sign element execution at same time, which is unrealistic with straight control strategy. Along these lines, fluffy rationale controller has been potential capacity to enhance the power of converters. The essential plan of a fluffy rationale controller is appeared in Fig 4 and comprises of four main parts, for example, numerical model [10].



Fig.2. Block diagram of the Fuzzy Logic controller (FLC) for proposed converter

PROPOSED CONTROL STRATEGY

Instead of active and reactive power , Active current and reactive current are obtained in (6) as the control variables in order to reduce the current spikes due to the initial phase error or grid fault.

Table 1. Typical line parameters

Type of Line	R(Ω/km)	X(Ω/km)	R/X (p.u)
Low voltage line	0.642	0.083	7.7
Medium voltage line	0.161	0.190	0.85
High voltage line	0.06	0.191	0.31

extent III, the customary hang control strategy introduces a decoupled trademark between P, Q and δ, E to the detriment of disregarding the line resistance. The proposed technique decouples Ia' and Ir' with thought of the line resistance, hence, it is suitable for microgrid application.

$$\begin{bmatrix} I_a \\ I_r \end{bmatrix} = \frac{1}{U} \begin{bmatrix} P \\ Q \end{bmatrix} = \begin{bmatrix} \frac{1}{Z^2}[R(E\cos\delta - U) + XE\sin\delta] \\ \frac{1}{Z^2}[X(E\cos\delta - U) - RE\sin\delta \end{bmatrix} (12)$$

Study Article

$$\begin{bmatrix} I'_a \\ I'_r \end{bmatrix} = T \begin{bmatrix} I_a \\ I_r \end{bmatrix} = \begin{bmatrix} \frac{E\sin\delta}{Z} \\ \frac{E\cos\delta - U}{Z} \end{bmatrix} (13)$$

$$\text{Where } T = \begin{bmatrix} \sin\theta & -\cos\theta \\ \cos\theta & \sin\theta \end{bmatrix} = \begin{bmatrix} \frac{X}{Z} & -\frac{R}{Z} \\ \frac{R}{Z} & \frac{X}{Z} \end{bmatrix} (14)$$

The proposed control is indicated graphically in Fig. 4, Ia0' and Ir0' are the changed dynamic and receptive current reference, ω0 and U0 are the inverter yield rakish recurrence and voltage sufficiency without burden, Vref is the inverter yield voltage reference which is combined by ω and E. Three stage immediate force hypothesis [3] is utilized to ascertain the inverter yield dynamic force P and responsive force Q. The network T is the orthogonal change for decoupled control in (4). The hang elements of the proposed procedure are given by (5) and (6).

$$\omega - \omega^0 = -K^{pb} \cdot (I_a - I_a^{00}) - K^{ia} \cdot \int_r^{-\infty} (I_a - I_a^{00}) dt - K^{pq} \cdot \frac{dI_r}{dt} (12)$$



Fig. 3. Frequency and voltage droop characteristics as a function of modified active and reactive power



Fig.4 Proposed control scheme using in three phase voltage source inverter

The overall diagram of the proposed control scheme using in three phase voltage source inverter applications is givengraphically in Fig. 5. As seen, only the inverter output voltage uabc and output current iabcwhich are locally measurable are using to implement the proposed control scheme. The control scheme can be implemented where the feedback information are converted to digital values first and power calculation is done. Then the transformed active and reactive current are calculated to realize the droop control algorithm and power sharing control, finally the PWM driving signals are produced through the inner voltage regulation control.

BLOCK DIAGRAM OF RENEWABLE BASED DG SYSTEM



Fig. 4 Simulation results: (a) Grid voltages, (b) Grid Currents (c) Unbalanced

load currents, (d) Inverter Currents



Fig. 5 Simulation results: (a) PQ-Grid, (b) PQ-Load, (c) PQ-Inverter, (d) dc-link voltage.

CONCLUSION

A 3-stage 4-wire renewable vitality framework with network interfacing inverter to enhance the nature of force at PCC is demonstrated. Hysteresis current control technique is utilized to produce door beats. The inverter is controlled to execute as a multi-capacity gadget by joining dynamic force channel usefulness. The voltage, current and force stream waveforms are gotten. Responsive force interest of the framework is repaid and current sounds is decreased. It has been observed that aggregate symphonious contortion of framework current is diminished from 13.02 to 5.22% and that heap current from 13.01 to 6.44%.

Study Article

REFERENCES

[1]. Mukhtiar Singh, Vinod Khadkikar ,Ambrish Chandra and Rajiv K. Varma,"Grid Interconnection of Renewable Energy Sources at the Distribution Level With Power-Quality Improvement Features", , IEEE transactions on power delivery, vol. 26, no. 1, january 2011

[2]. F. Blaabjerg, R. Teodorescu, M. Liserre, and A. V. Timbus, "Overview of control and grid synchronization for distributed power generation systems," IEEE Trans. Ind. Electron., vol. 53, no. 5, pp. 1398–1409,Oct. 2006.

[3]. J. M. Carrasco, L. G. Franquelo, J. T. Bialasiewicz, E. Galván, R. C.P. Guisado, M. Á. M.Prats, J. I. León, and N. M. Alfonso, "Power electronic systems for the grid integration of renewable energy sources: A survey," IEEE Trans. Ind. Electron., vol. 53, no. 4, pp. 1002– 1016, Aug. 2006.

[4]. Bart Meersman, Bert Renders, Lieven Degroote, Tine Vandoorn,Jeroen De Kooning and Lieven Vandevelde," Overview of three-phase inverter topologies for distributed generation purposes" April 18-21, 2010

[5]. U. Borup, F. Blaabjerg, and P. N. Enjeti, "Sharing of nonlinear load in parallel-connected three-phase converters," IEEE Trans. Ind. Appl.,vol. 37, no. 6, pp. 1817–1823, Nov./Dec. 2001

